CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.14/KRIDL/CSR-08/107s/AGG/GR/2016-17 : 03.08.2016

TEST REPORT ON DETERMINATION GRADATION OF COARSE AGGREGATES

* Customer	: **Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	: **Technical Manager,** KRIDL, Bangalore.
* Name of Work	: Construction of Park on Pipeline Road from Vijyashree School to Janapriya Apartment Hesaraghatta Main Road Ward No.14, BBMP, Bangalore.
* Reference	: EE/PD/DZ/WO/15/2015-16 Dated: 28.03.2016
Technical Reference	: IS : 2386 Part 1 -1963 RA-2007
Sample ID	: Coarse Aggregates (20mm)
Sample Received on	: 01.08.2016
Date of Testing	: 03.08.2016

CIVIL ENGINEERING TESTING LABORATORY www.civiltechconsultants.com

Total Wt. of Aggregates in gms= **5000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS :383-1970 (RA- 2007)	
		Graded	Single Sized
40	100	100	100
20	97.00	95-100	85-100
10	31.90	25-55	0-20
4.75	4.90	0-10	0-5

* Information is furnished by the Customer/Representative

Remarks : This sample is under Graded specific limits

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laborator
3. Any Query regarding the report must be reported within 30 days from the date of testing.

AE(P)

pl. Verify & put up

****

VISHWANATH C.
Quality Manager

Civil-Tech Consultants & Engineers Bangalore

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara

Ravi N.C.
AE Project

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com